

GOVERNMENT OF ANDHRA PRADESH
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT

From :
The Director General,
State Disaster Response and Fire Services,
Andhra Pradesh, Vijayawada.

To :
The Management,
M/s Viswam EM High School,
Thattivaripalle Angallu,
Kurabalakota (M), Chittoor District.

Re.No.15422/CTR/RFO/2020 (MSB-SR), Dated: 01-05-2022.

Sir,

Sub: A.P. State Disaster Response and Fire Services Department-
MSB Section-Issuance of Renewal of No Objection Certificate to the
Existing Building of M/s Viswam EM High School (Viswam Educational
Society), represented by M.Prabhakar Reddy, Sy.No.123,
Chintaihgarikota Road, Thattivaripalle, Angallu (GP), Kurabalakota (M),
Chittoor District-Regarding.

- Ref: 1. Occupancy NOC File No.15422/CTR/RFO/2020, Dt:07.12.2020 of
Regional Fire Officer, Southern Region, Vijayawada.
2. Application of M/s Viswam EM High School (Viswam Educational
Society), represented by M.Prabhakar Reddy, Sy.No.123,
Chintaihgarikota Road, Thattivaripalle, Angallu (GP),
Kurabalakota (M), Chittoor District.


The Management of M/s Viswam EM High School (Viswam Educational Society),
represented by M.Prabhakar Reddy, Sy.No.123, Chintaihgarikota Road, Thattivaripalle,
Angallu (GP), Kurabalakota (M), Chittoor District has requested to issue Renewal of
No Objection Certificate by duly remitting the Renewal Fee towards Fire Precautionary Fee
vide reference 2nd cited.

2) The No Objection Certificate for Occupancy was issued vide reference 1st cited to
the Existing Building of M/s Viswam EM High School (Viswam Educational Society),
represented by M.Prabhakar Reddy, Sy.No.123, Chintaihgarikota Road, Thattivaripalle,
Angallu (GP), Kurabalakota (M), Chittoor District with Cellar + Ground + 03 Upper Floors with
Built-up area of 8565.44 Sq.Mtrs., with a Height of 13.05 Mtrs., for Educational Occupancy.

3) The Management has submitted the Self-Certification report and stated that the
furnished information is correct and it is noticed at any time that the information provided is
false, they understand that Renewal NOC deemed may be cancelled by the concerned
authority.

4) In view of the above and taking into consideration of the larger public interest and
in the context of the COVID-19 pandemic across the country and also based on the Self-
Certification submitted by the Management, the Renewal of No Objection Certificate is issued
to the Existing Building of M/s Viswam EM High School (Viswam Educational Society),
represented by M.Prabhakar Reddy, Sy.No.123, Chintaihgarikota Road, Thattivaripalle,
Angallu (GP), Kurabalakota (M), Chittoor District with Cellar + Ground + 03 Upper Floors with
Built-up area of 8565.44 Sq.Mtrs., with a Height of 13.05 Mtrs., for Educational Occupancy.

(contd.....2p)


PRINCIPAL
Viswam E.M. High School
Affiliated to CBSE - New Delhi
CBSE Affi. No. 130605
Angallu (Po), Kurabalakota (Mdt)
Annamayya Dist., A.P.

Viswam Educational Society

Secretary Cum Correspondent

5) It is suggested to the Management for providing the following Fire Safety Measures keeping in view of Practicality, Maintenance and Resilience.

Sl. No.	Fire Fighting Equipment	Prescribed	Available with Nos.	Deficit
1	Fire Extinguishers	ABC/CO2 type	89 Nos.	Nil
2	Underground parking/ Cellar / Basement	Temperature Sensors connected to "Hooter" and that can give alerts through Cell phone instead of Sprinklers.	Provided	Nil
3	Manual Call Point System	One Number per Floor	05 Nos.	Nil
4	Under Ground Static Water Tank (or) Terrace Water Tank.	5,000 Ltrs. (Minimum)	15,000 Ltrs.	Nil
5	2 HP (Pump + Electrical Motors connected) @ one per Floor connected to Normal Plumbing System instead of Down Comer/Special Pipes.	One per each Floor (Total 05 Floors)	04 Nos.	Nil
6	5 HP (Mobile Pump + Petrol Engine on wheels connected to Ground Floor Sump).	One Number	01 No.	Nil

6) Electrical Safety System:

(i) Miniature Circuit Breakers, MCB's.	:	Yes, Provided
(ii) No Overloading of Power Sockets.	:	Yes, Ensured
(iii) Whether, 10 years old wiring to be changed specially wherever A/c is there ?	:	Yes, Ensured
(iv) LED Lights in Closed Rooms, Corridors, Staircases connected to Inverter (Battery).	:	Yes, Connected
(v) Grounding/Earthing is provided.	:	Yes, Provided
(vi) Lightening Conductor is provided.	:	Not Applicable
(vii) The above shall be certified by authorized Electrical Contractor/Supervisor.	:	Yes, Certified

7) Fire Safety Suggestions:

Sl. No.	As Builder	As Occupant	As Security personnel
1.	All the Fire protection arrangements shall be maintained in good working condition at all time.	The Escape/Exit roots shall not be kept Locked/Blocked or Encroached.	All the occupants must be trained the correct method of operation of the Fire Fighting System installed.
2.	Any loss of life or property due to non-functioning of Fire Safety Measures and other Installations shall be the responsibility of the management.	All occupants shall be trained to operate the Fire Safety Equipment during Emergency.	Mock Drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months.
3.	Addition/Alteration, if any in the Building may be verified by Building Authority.	Mock Drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months.	All Security Personnel shall be trained to operate the Fire Safety Equipment during Emergency.
4.	This Renewal of No Objection Certificate is only from Fire Safety Point of View.	Raise the alarm If the Fire cannot be controlled, Evacuate the area completely at once with nearest Safe Exit.	Attack the Fire using available Fire Equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing Doors and Windows.

(contd.....3p)


S. Dennis
PRINCIPAL
Viswam E.M. High School
 Affiliated to CBSE - New Delhi
 CBSE Affi. No. 130605
 Angallu (Po), Kurabaiakota (Mdl)
 Annamaya Dist., A.P.

Viswam Educational Society

[Signature]
 Secretary Cum Correspondent

8) This Renewal of No Objection Certificate is valid for a period of Five (05) years from the date of issue of this letter to the Management of M/s Viswam EM High School (Viswam Educational Society), represented by M.Prabhakar Reddy, Sy.No.123, Chintaihgarikota Road, Thattivaripalle, Angallu (GP), Kurabalakota (M), Chittoor District subject to the compliance of above Fire and Electrical Safety Measures. The Owner/ Occupier/ Builder/ Management concerned of the Building shall submit Self Declaration/Certification with regard to working condition of above Fire Safety System every year in the prescribed format and submit/upload the photographs of the Mock Drills conducted in the premises. It is the responsibility of the Builder to maintain the Fire Safety Equipment in good working condition at all times and apply for next Periodical Renewal of No Objection Certificate, duly remitting the User Charges vide G.O.Ms.No.90, Home (Prisons & Fire Services) Department Dated:13.08.2021 & G.O.Ms.No.120, Home (Prisons & Fire Services) Department Dated:25.10.2021, two (02) months before expiry of this Renewal of No Objection Certificate.


Yours Sincerely,


Director General,


State Disaster Response and Fire Services,
Andhra Pradesh, Vijayawada.

Copy to the Management, M/s Viswam EM High School (Viswam Educational Society), represented by M.Prabhakar Reddy, Sy.No.123, Chintaihgarikota Road, Thattivaripalle, Angallu (GP), Kurabalakota (M), Chittoor District.
Copy to the District Educational Officer, Chittoor.

Note: In case of any emergency call to 101 or State Fire Control Room-9100108101.


PRINCIPAL
Viswam E.M. High School
Affiliated to CBSE - New Delhi
CBSE Affl. No. 130605
Angallu (Po), Kurabalakota (Mdl)
Annamayya Dist., A.P.

Viswam Educational Society


Secretary Cum Correspondent